



Cheshire West and Chester

PRIVATE WATER SUPPLIES REGULATIONS 2016

GREAT BUDWORTH SPRING – PRIVATE WATER SUPPLY

SCHEDULE OF RESULTS

Date of Sample: 6 June 2025

Location: Great Budworth Spring - outlet

PARAMETER	RESULT	CONCENTRATION OR VALUE
Nitrate	46.137	50mg/l
Nitrite	0.00985	0.5mg/l
Colony Count 22 C	0	No abnormal change
Colony Count 37 C	0	No abnormal change
Enterococci	0	0/100ml
E. Coli	0	0/100ml
Coliforms	0	0/100ml

INTERPRETATION AND COMMENTS

SATISFACTORY results

Note: Tested by United Utilities, Lingley Mere Laboratory, Warrington.