



Cheshire West and Chester

PRIVATE WATER SUPPLIES REGULATIONS 2016

GREAT BUDWORTH SPRING – PRIVATE WATER SUPPLY

SCHEDULE OF RESULTS

Date of Sample: 30 September 2025 and resample on 13 October 2025

Location: Great Budworth Spring - outlet

PARAMETER	RESULT	RESAMPLE RESULT	CONCENTRATION OR VALUE
Enterococci	0		0/100ml
Nitrate	51.864	53.983	50mg/l
Nitrite	0.00755		0.5mg/l
Colony Count 22 C	0		No abnormal change
Colony Count 37 C	0		No abnormal change
E. Coli	0		0/100ml
Coliforms	0		0/100ml

INTERPRETATION AND COMMENTS

UNSATISFACTORY results

Note: Tested by United Utilities, Lingley Mere Laboratory, Warrington.